November 12, 2025

SUBJECT: VILLAGE OF HOFFMAN ESTATES
2025 SANITARY SEWER REHABILITATION
CLARIFICATIONS AND RESPONSE TO QUESTIONS

To Whom It May Concern:

This letter is meant to clarify some questions and concerns regarding the 2025 Sanitary Sewer Rehabilitation Project. This is not considered an addendum, but an additional resource for your information and consideration.

- The contract and performance bond attached to the back of the bid packet were included for reference. They are not required to be completed with your bid submittal.
- There is no recent CCTV footage available for the sanitary sewers. Preliminary CCTV footage obtained during this project will be reviewed by the Engineer for lining feasibility.
- The Village will not provide a location for disposing of debris. It will be the responsibility of the
 contractor to dispose of debris material removed from the system, off-site, in accordance will all
 applicable regulations.
- Water and Steam are acceptable methods for the liner curing. ASTM F2019 which specifies the UV-Light curing method is also acceptable.
- Accurate manhole depth information is not available; it is required to be verified by the contractor. No manholes for lining exceed 15 ft in depth.

The above clarifications have been made to assist you in preparing your bid. Thank you for your consideration.

Sincerely,

Andy LoBosco, P.E. Senior Project Manager

Andy LoBosco