



HOFFMAN ESTATES

DEPARTMENT OF PUBLIC WORKS

July 6, 2026

**SUBJECT: VILLAGE OF HOFFMAN ESTATES
2026 FIRE HYDRANT PURCHASE
ADDENDUM NO. 1**

To Whom It May Concern:

Please make reference of the following clarifications and changes to the above bid:

Response to Bidder's Questions:

1. Regarding the cast iron valve boxes along with MJ accessories, do you want the hydrants bid each with a two-piece valve box, water lid, and stabilizer, or do you want us to bid only the hydrant and AUX valve? Secondly, do you require the valve boxes to be domestic, or will you accept import?

HYDRANTS SHALL BE BID WITH AT TWO-PIECE VALVE BOX, WATER LID, AND PLASTIC STABILIZER (LINCOLN-CAP). VALVE BOXES ARE NOT REQUIRED TO BE DOMESTICALLY MANUFACTURED.

THE CLARIFICATIONS TO THE ABOVE DOCUMENTS MUST BE REFLECTED IN THE BIDS SUBMITTED TO THE VILLAGE.

Thank you,

Ryan M. Christensen
Superintendent of Water and Sewer